

**Eatonville Police Department**  
**Incident NCIC=WA0270500**  
**And Incident Date Reported BETWEEN 09/01/2013**  
**And 09/30/2013**

**Incident Log Report**

**Printed On: Wed, Oct 02, 2013**

<i>Case Number</i>	<i>NCIC</i>	<i>Date Reported</i>	<i>Officer</i>	<i>Offense</i>
<i>Location</i>				
2013000326	WA0270500	09/02/2013 07:47	EA1	Found Narcotics
2013000327	WA0270500	09/02/2013 10:33	EA1	Burglary, Theft 2
2013000328	WA0270500	09/02/2013 16:15	E5	MVTR
2013000329	WA0270500	09/03/2013 17:50	ea7	PSP 2
2013000330	WA0270500	09/03/2013 22:20	ea7	Fail to Transfer Title
2013000331	WA0270500	09/05/2013 10:31	E4	Warrant Arrest
2013000332	WA0270500	09/05/2013 11:17	E4	Trespass Notification
2013000333	WA0270500	09/06/2013 12:51	E4	Civil Issue, Info
2013000334	WA0270500	09/06/2013 21:04	11	MIP
2013000335	WA0270500	09/09/2013 06:20	EA1	Burglary
2013000336	WA0270500	09/09/2013 07:48	EA1	MVC Non-Injury
2013000337	WA0270500	09/09/2013 14:43	E1	Agency Assist, Death Notification
2013000339	WA0270500	09/10/2013 12:27	E4	Reckless Endangerment, DWLS 3
2013000340	WA0270500	09/10/2013 21:00	E5	Verbal Domestic
2013000341	WA0270500	09/11/2013 10:00	E4	DWLS 3
2013000342	WA0270500	09/12/2013 00:45	E4	Call Out-Poss Domestic
2013000343	WA0270500	09/12/2013 19:11	ea7	Temporary Criminal Trespass Order Notification
2013000344	WA0270500	09/13/2013 10:03	E4	Animal at large
2013000345	WA0270500	09/14/2013 15:38	ea7	DWLS 3
2013000346	WA0270500	09/14/2013 22:54	ea7	Juvenile Problem
2013000347	WA0270500	09/16/2013 09:38	EA1	Mal-Misch 3
2013000348	WA0270500	09/17/2013 15:19	ea7	Dog Complaint
2013000349	WA0270500	09/18/2013 18:11	ea7	DWLS 3
2013000350	WA0270500	09/19/2013 15:35	ea7	MVTR
2013000351	WA0270500	09/21/2013 21:54	ea7	Reckless Driving, Fail to Transfer Title
2013000352	WA0270500	09/25/2013 23:58	E5	MVC Non-Injury
2013000353	WA0270500	09/26/2013 20:06	E5	Vehicle Prowl 2, Theft2
2013000354	WA0270500	09/28/2013 12:56	98999	Void
2013000355	WA0270500	09/28/2013 19:48	E5	Verbal Domestic
2013000356	WA0270500	09/30/2013 13:21	EA1	Theft 3

Eatonville Police Department

Incident Log Report

Printed On: Wed, Oct 02, 2013

<i>Case Number</i>	<i>NCIC</i>	<i>Date Reported</i>	<i>Officer</i>	<i>Offense</i>
2013000357	WA0270500	09/30/2013 14:37	EA1	Welfare Check

Total Records: 31

**Eatonville Police Department**  
**Citation NCIC=WA0270500**  
**And Citation Date Cited BETWEEN 09/01/2013**  
**And 09/30/2013**

**Citation Log Report**

**Printed On: Wed, Oct 02, 2013**

Citation Nbr	NCIC	Date/Time Cited	Officer	Offense
C3Z0039195	WA0270500	9/11/2013 10:00	E4	DWLS 3
C3Z0645071	WA0270500	9/3/2013 22:20	ea7	Fail to Transfer Title
C3Z0772637	WA0270500	9/14/2013 15:38	ea7	DWLS 3
C3Z0772639	WA0270500	9/18/2013 18:11	ea7	DWLS 3
C3Z0772642	WA0270500	9/21/2013 21:54	ea7	Reckless Driving, Fail to Transfer Title
I3Z0039194	WA0270500	9/5/2013 14:54	E4	64/50
I3Z0039196	WA0270500	9/17/2013 11:36	E4	51/35
I3Z0380271	WA0270500	9/17/2013 10:03	E4	Animal at large
I3Z0595491	WA0270500	9/26/2013 00:01	E5	Speed Fast for Conditions w/MVC, No Ins
I3Z0758239	WA0270500	9/4/2013 20:10	E5	43/25
I3Z0758240	WA0270500	9/10/2013 20:27	E5	No/Illegal Front Plate
I3Z0758241	WA0270500	9/10/2013 23:27	E5	69/50
I3Z0758242	WA0270500	9/17/2013 19:10	E5	44/25
I3Z0758243	WA0270500	9/24/2013 21:37	E5	NVOL W/ID, No Insurance, Def Tail
I3Z0772630	WA0270500	9/3/2013 22:20	ea7	Cell Phone Use While Driving
I3Z0772633	WA0270500	9/3/2013 17:50	ea7	Driving on Sidewalk, No MC Helmet
I3Z0772634	WA0270500	9/12/2013 16:14	ea7	Helmet Required
I3Z0772635	WA0270500	9/12/2013 17:34	ea7	Illegal Studded Tires, No Ins, No Reg
I3Z0772636	WA0270500	9/12/2013 19:26	ea7	Helmet Required
I3Z0772638	WA0270500	9/14/2013 15:38	ea7	No Insurance, No Registration
I3Z0772640	WA0270500	9/19/2013 17:07	ea7	45/25
I3Z0772641	WA0270500	9/20/2013 16:45	ea7	48/25
I3Z0772643	WA0270500	9/21/2013 21:54	ea7	Reckless Driving, Fail to Transfer Title

*FIRE & EMS*

PO Box 291, 201 Center ST West Eatonville, WA 98328  
PHONE: 360-832-6931 Fax: 360-832-2931  
eatonvillefire@eatonville-wa.gov

*Monthly Report  
September 2013*

9 Fire  
5 Auto Accident  
49 Aid  
7 Service  
70 Total

Mutual aid responses with District 17 -- 19  
Mutual aid responses with District 23 -- 11  
Mutual aid response with District 21 -- 0  
Mutual aid responses with NPS -- 0

2012 YEAR TO DATE TOTAL -- 501  
2013 YEAR TO DATE TOTAL -- 519

Transports -- 31  
ALS -- 23  
BLS -- 8

2012 transports year to date -- 213  
2013 transports year to date -- 235

For the month of September the total amount billed for ambulance transports was \$41,471.00.

Total amount billed for ambulance transports to date -- \$318,900.00

# Eatonville Fire Department


Eatonville, WA

This report was generated on 10/7/2013 10:03:20 AM



## Breakdown by Major Incident Types for Date Range

Start Date: 09/01/2013 | End Date: 09/30/2013



MAJOR INCIDENT TYPE	# INCIDENTS	% of TOTAL
Fires	1	1.43%
Rescue & Emergency Medical Service	54	77.14%
Service Call	6	8.57%
Good Intent Call	8	11.43%
Special Incident Type	1	1.43%
<b>TOTAL</b>	<b>70</b>	<b>100.00%</b>

Only REVIEWED incidents included. Summary results for a major incident type are not displayed if the count is zero.

**Detailed Breakdown by Incident Type**

<b>INCIDENT TYPE</b>	<b># INCIDENTS</b>	<b>% of TOTAL</b>
111 - Building fire	1	1.43%
311 - Medical assist, assist EMS crew	1	1.43%
320 - Emergency medical service, other	7	10.00%
321 - EMS call, excluding vehicle accident with injury	41	58.57%
322 - Motor vehicle accident with injuries	2	2.86%
324 - Motor vehicle accident with no injuries.	3	4.29%
500 - Service Call, other	4	5.71%
551 - Assist police or other governmental agency	2	2.86%
611 - Dispatched & cancelled en route	7	10.00%
651 - Smoke scare, odor of smoke	1	1.43%
900 - Special type of incident, other	1	1.43%
<b>TOTAL INCIDENTS:</b>	<b>70</b>	<b>100.00%</b>

Only REVIEWED incidents included. Summary results for a major incident type are not displayed if the count is zero.

# Eatonville Fire Department


Eatonville, WA

This report was generated on 10/7/2013 10:06:31 AM



## Incident Type Count per Zone for Date Range

Start Date: 09/01/2013 | End Date: 09/30/2013



ZONES	INCIDENT TYPE	COUNT
<b>17 - South Pierce</b>		
	111 - Building fire	1
	321 - EMS call, excluding vehicle accident with injury	10
	324 - Motor vehicle accident with no injuries.	2
	500 - Service Call, other	1
	551 - Assist police or other governmental agency	1
	611 - Dispatched & cancelled en route	4
	<i>Total Incidents for 17 - South Pierce:</i>	<b>19</b>
<b>23 - Ashford/Elbe</b>		
	320 - Emergency medical service, other	1
	321 - EMS call, excluding vehicle accident with injury	6
	322 - Motor vehicle accident with injuries	1
	611 - Dispatched & cancelled en route	3
	<i>Total Incidents for 23 - Ashford/Elbe:</i>	<b>11</b>
<b>84 - Eatonville</b>		
	311 - Medical assist, assist EMS crew	1
	320 - Emergency medical service, other	6
	321 - EMS call, excluding vehicle accident with injury	25
	322 - Motor vehicle accident with injuries	1
	324 - Motor vehicle accident with no injuries.	1
	500 - Service Call, other	3

Zone information is defined on the Basic Info 3 screen of an incident.  
Only REVIEWED incidents included.

ZONES	INCIDENT TYPE	COUNT
	551 - Assist police or other governmental agency	1
	651 - Smoke scare, odor of smoke	1
	900 - Special type of incident, other	1
	<i>Total Incidents for 84 - Eatonville:</i>	<i>40</i>
	<b><i>Total Count for all Zone:</i></b>	<b><i>70</i></b>

Zone information is defined on the Basic Info 3 screen of an incident.  
Only REVIEWED incidents included.



# Building Department Activity 2013

	Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sept	Oct	Nov	Dec	Totals
Plan Review	2	0	0	4	5	5	4	3	3	0	0	0	26
Foundation	0	0	0	1	3	3	2	7	5	0	0	0	21
Footing drains	0	0	0	0	1	5	0	4	2	0	0	0	12
Floor Framing	0	0	0	1	1	4	0	2	1	0	0	0	9
Shearwall	0	0	0	0	1	3	0	0	2	0	0	0	6
Sewer	0	0	0	0	1	0	0	1	2	0	0	0	4
Water	0	0	0	0	1	2	0	1	4	0	0	0	8
Storm	0	0	2	1	1	2	0	1	2	0	0	0	9
Framing	2	0	0	0	1	1	5	1	2	0	0	0	12
Plumbing	2	2	0	0	2	1	5	1	4	0	0	0	17
Mechanical	2	1	2	1	1	1	6	1	2	0	0	0	17
Insulation	1	1	0	0	1	0	1	1	2	0	0	0	7
Sheetrock	0	0	0	0	1	0	5	1	0	0	0	0	7
Patio	0	0	0	0	0	0	1	1	2	0	0	0	4
Final	1	1	0	0	0	1	1	5	3	0	0	0	12
Red Tags	1	0	0	1	0	0	0	0	1	0	0	0	3
OTHERS	5	6	7	6	6	5	8	16	15	0	0	0	74
<b>TOTAL</b>	<b>16</b>	<b>11</b>	<b>11</b>	<b>15</b>	<b>26</b>	<b>33</b>	<b>38</b>	<b>46</b>	<b>52</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>248</b>

Planning and Counsel meetings  
 Hand out door Hangars  
 Training Classes

EATONVILLE POWER AND LIGHT  
SEPTEMBER  
SUPERINTENDENT DANSHARPE LINEMEN NESTOR SUNDITA APPRENTICE JESSE CARROLL

Street lights

Repaired stlight at parks  
Replaced street light on Joy Street  
Community center lights  
Street light at 531 sr 161

Parks

Mowed mill pound parks  
Town square  
Picked up garbage  
Fixed mower

Locates

8 locates around town

Banners

Took down 1 banner  
Put 1 banner up  
Took down flower pot  
Took down flags

Reconnect & Disconnect

Disconnect 15  
Reconnect 15

New hook ups

455 airport rd  
New service hookup 122orchard  
116 antone repair  
114 mashell repair

Trim trees Larson st.

## Priority 1

**9-1-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-2-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-2-13 Inspect sewer project on Madison.**

Due Date: None  
Category: Wastewater

**9-2-13 Hose SBR's.**

Due Date: None  
Category: Wastewater

**9-2-13 Clean Soda ash line at WTP.**

Due Date: None  
Category: Water

**9-3-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-3-13 Fix bathroom at park.**

Due Date: None  
Category: Parks

**9-3-13 Meter reads.**

Due Date: None  
Category: Water

**9-3-13 Fix water leak on Eatonville Hwy.**

Due Date: None  
Category: Water

**9-4-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-4-13 Work late and help get sewer street crossing done on Madison.**

Due Date: None  
Category: Wastewater

**9-4-13 Hose headworks.**

Due Date: None  
Category: Wastewater

**9-4-13 Work late to fix WTP CL2 level due to changing source water conditions.**

Due Date: None  
Category: Water

**9-5-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-5-13 Set up parts to pull and replace neutralization pump at WTP.**

Due Date: None  
Category: Water

**9-5-13 Work on retrieval gear crank.**

Due Date: None  
Category: Water/Sewer

**9-6-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-6-13 Clean headworks and bar screen.**

Due Date: None  
Category: Wastewater

**9-6-13 Print and mail cross connection letters.**

Due Date: None  
Category: Water

**9-6-13 Get caught up on meter reads.**

Due Date: None  
Category: Water/Sewer

**9-6-13 Stage beauty bark at parks for volunteers.**

Due Date: None  
Category: Parks

**9-6-13 Clear blocked storm drains in flood.**

Due Date: None  
Category: Storm

**9-6-13 Finish and mail WTP monthly report.**

Due Date: None  
Category: Water

**9/9/13 Locate parts to repair WTP raw water strainer. Going to send price quote.**

Due Date: None  
Category: Water

**9/9/13 Test and pull Flyght sludge pump from SBR transfer tank. Needs sent out and repair and rebuild. Not working.**

Due Date: None  
Category: Wastewater

**9-9-13 Still doing two CIP's per day on the backwash skid at the WTP. Mashell river full of organics.**

Due Date: None  
Category: Water

**9-9-13 Pull the required water samples for the month of Sept. for Water Management.**

Due Date: None  
Category: Water

- 9/11/13 Daily two CIP's on the backwash skid.**

Due Date: None  
Category: Water

- 9-11-11 Repair 2" discharge line from the neutrazation basin to the MH at Mill Pond Park. Tribe workers drove over it when they were watering their trees.**

Due Date: None  
Category: Water

- 9/11/13 See what is wrong with a reported fire hydrant problem that was turned in.**

Due Date: None  
Category: Water

- 9/11/13 Clean floor at the WTP.**

Due Date: None  
Category: Water

- 9-12-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-12-13 Help power crew clear brush on Larson.**

Due Date: None  
Category: Power and Light

- 9-12-13 Meter re-reads.**

Due Date: None  
Category: Water/Sewer

- 9-12-13 Hose SBR's.**

Due Date: None  
Category: Wastewater

- 9-12-13 Hose headworks.**

Due Date: None  
Category: Wastewater

- 9-13-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-13-13 Dig and preform cremation grave**

Due Date: None  
Category: Parks

- 9-13-13 Fix water leak on Washington S.**

Due Date: None  
Category: Water

- 9-13-13 Instal new 1.5" Meter at apartments on Wash S.**

Due Date: None  
Category: Water

- 9-14-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-15-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-16-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-16-13 Work on raw water stainer at WTP.**

Due Date: None  
Category: Water

- 9-16-13 Start meter reads.**

Due Date: None  
Category: Water/Sewer

- 9-16-13 Look at proposed project on Lynch.**

Due Date: None  
Category: Water/Sewer

- 9-16-13 Inspect sidewalk on Madison.**

Due Date: None  
Category: Streets

- 9-17-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

- 9-17-13 Meter reads.**

Due Date: None  
Category: Water/Sewer

- 9-17-13 Fix water line by airport.**

Due Date: None  
Category: Water

- 9-17-13 Calibrate pH meters on water filters at WTP.**

Due Date: None  
Category: Water

- 9-17-13 Change acid barrel at WTP.**

Due Date: None  
Category: Water

- 9-17-13 Move CL2 from WTP to WWTP.**

Due Date: None  
Category: Water/Sewer

- 9-17-13 Hose floor at WTP.**

Due Date: None  
Category: Water

- 9-17-13 Offload chemical delivery.**

Due Date: None  
Category: Water

- 9/18/13 Hose SBR tanks.**

Due Date: None  
Category: Unfiled

- 9/18/13 Work on Diaphragm portable pump. Will not start and need for next water leak. Need take it to honda dealer in Yelm for repair.**  
 Due Date: None  
 Category: Unfiled
- 9/18/13 Two CIP on backwash skid.**  
 Due Date: None  
 Category: Unfiled
- 9/18/13 Hose chemical room floor out.**  
 Due Date: None  
 Category: Unfiled
- 9-19-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-19-13 Fix chemical leak at WTP.**  
 Due Date: None  
 Category: Water
- 9-19-13 Hose SBR's.**  
 Due Date: None  
 Category: Wastewater
- 9-20-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-20-13 Meter reads.**  
 Due Date: None  
 Category: Water/Sewer
- 9-20-13 Multiple CIP's at WTP.**  
 Due Date: None  
 Category: Water
- 9-21-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-22-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-23-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-23-13 Clean WWTP.**  
 Due Date: None  
 Category: Wastewater
- 9-23-13 Work on 2014 budget.**  
 Due Date: None  
 Category: Water/Sewer

- 9-23-13 Update cross connection sytem.**  
 Due Date: None  
 Category: Water
- 9-23-13 Clean headworks.**  
 Due Date: None  
 Category: Wastewater
- 9-24-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-24-13 Work on raw water screen at WTP.**  
 Due Date: None  
 Category: Water
- 9-24-13 Hose SBR's.**  
 Due Date: None  
 Category: Wastewater
- 9-24-13 Fill pot holes.**  
 Due Date: None  
 Category: Streets
- 9-25-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-25-13 Work on cracked raw water piping at WTP. Order parts for emergency repair if needed.**  
 Due Date: None  
 Category: Water
- 9-25-13 Work on sweeper.**  
 Due Date: None  
 Category: Streets
- 9-25-13 Get prices and work on budget.**  
 Due Date: None  
 Category: Water/Sewer
- 9-26-13 Water and wastewater daily lab testing and system checks.**  
 Due Date: None  
 Category: Water/Sewer
- 9-26-13 Get more prices for budget.**  
 Due Date: None  
 Category: Water/Sewer
- 9-26-13 Attempt temporary fix on raw water pipe at WTP. Note- didn't work.**  
 Due Date: None  
 Category: Water
- 9-26-13 Fill pot hole around town and alleys.**  
 Due Date: None  
 Category: Streets

**9-27-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-27-13 Hose SBR's.**

Due Date: None  
Category: Wastewater

**9-27-13 Meter re-reads.**

Due Date: None  
Category: Water/Sewer

**9-27-13 Preparing for rain storm go around town and clear storm catch basins.**

Due Date: None  
Category: Storm

**9-27-13 Hose headworks and clean bar screen.**

Due Date: None  
Category: Wastewater

**9-28-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-28-13 Power outage. Come in to reset water and wastewater plants.**

Due Date: None  
Category: Water/Sewer

**9-29-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-29-13 Another power blip, have to reset plants and check lift stations.**

Due Date: None  
Category: Water/Sewer

**9-30-13 Water and wastewater daily lab testing and system checks.**

Due Date: None  
Category: Water/Sewer

**9-30-13 Hose SBR's.**

Due Date: None  
Category: Wastewater

**9-30-13 Use sweeper to clean up around town after wind storm.**

Due Date: None  
Category: Streets

**9-30-13 Continue work on budget.**

Due Date: None  
Category: Water/Sewer

**9-30-13 Fix cracked Y strainer on CL2 line at WTP. Also check/clean all Y strainers.**

Due Date: None  
Category: Water

**9-30-13 Locates around town for rain gardens.**

Due Date: None  
Category: Water/Sewer

**9-30-13 Wells dirty from storm, have to run multiple CIP's to keep backwash skid running.**

Due Date: None  
Category: Water